



# SEWAGE ITEMS FOR 2011

# Sewage Items for 2011–Mound and Drip Inspections

- Requires 3-4 inspections
- Must call into clerks office for each inspection
- Inspections include
  - Chisel plowing
  - Addition of sand and piping
  - Start up
  - Final cover

# Sewage Items for 2011–Mounds and Chisel Plowing

- Chisel plowing must be completed when ground is dry.
- Can not use teeth of backhoe unless they are special fitted teeth. Backhoe teeth are too short and wide for proper chisel plowing.
- Chisel plow basal area

# Sewage Items for 2011–Working Around a Mound

- All work must be completed on the upslope side of mound to prevent compaction.

# Sewage Items for 2011– Protecting the Site

- When permit is issued by health department, the sewage treatment site must be roped or fenced off for protection.
- This includes the reserve area.



# WET WEATHER INSTALLS

MEL MEYERER TAPLIFT2



# AS BUILT DRAWINGS

V2 HOTEL DRAWINGS



# Sewage Items for 2011–New Rules Update